

| | | |
|---|---|--|
| H | REQUEST FOR PROPOSALS ADDENDUM | Skidmore Water Supply Corporation Bee County, Texas ATTN: Lisa Baker PO Box 290 Skidmore, Texas 78389 |
| | RFP Number: 22/23-004 Addendum #1 Page 1 of 1 Bid Due Date: December 5, 2022 @ 2:00 PM | |

Skidmore Water Supply Corporation
ARPA Request for Proposals
Generator Project

In accordance with the Request for Proposals, it is hereby amended as set forth below:

BE ADVISED THAT THE FOLLOWING CHANGES ARE APPLIABLE TO THE ABOVE REFERENCED REQUEST FOR PROPOSALS

QUESTION SUBMITTAL DEADLINE

The Question submittal deadline has been changed as noted herein, and modifies the deadline stated in the RFP. **The new Question submittal deadline is 2:00 pm on November 30, 2022.**

| Item | Section | Description of Change |
|------|---------------|---|
| 3 | Scope of Work | <p>Changed the following language describing the size of the (3) mobile generators from 60KW to 45KW the first sentence of the second Paragraph:</p> <p>(3) Mobile Generators: Lift Station Generator Project – 3 - 45KW Diesel trailer mounted mobile/towable generators, 3 phase 120/240V, 60HZ, 4 wire (camlock connections); along with 3 - 40' 2AWG 4 wire camlock load connections. Camlock connections already installed at lift stations (pictures of existing camlock connections below).</p> |

THIS ADDENDUM NOW BECOMES A PART OF THE ORIGINAL REQUEST FOR PROPOSALS RETURN THIS ADDENDUM ACKNOWLEDGEMENT FORM AS INSTRUCTED, FAILURE TO DO SO MAY RESULT IN DISQUALIFICATION OF RESPONSE.

1. Acknowledge receipt of this addendum by signing and returning this addendum via email to skidmorewatersupply@yahoo.com prior to November 30, 2022.

Authorized Signature: _____

Respondent Name: _____

Date: _____

Phone: _____

Email: _____